


# Seismic Lighting Fixture Clamp, One 0.61 x 0.61 m Fixture

NÚMERO DE CATÁLOGO

**SFCLTCF**



## CARACTERÍSTICAS

Secures fluorescent light fixtures to the ceiling frame members

Requires no additional chains, cables or slack wires attached to the fixture

Helps strengthen integrity of the T-Grid system

Holds in place against the force of standard fire-hose pressure

Meets U.S. building code and electrical code specifications

Also satisfies NEC® 410.16(C) positive attachment for secure fastening of luminaires (fixtures) complying with Building Code Reference AC184

Reusable and cost effective



## CARATERÍSTICAS DO PRODUTO

Número do artigo: 402245

Material: Aço

Acabamento: Plain

Fixture Configuration: One 0.61 x 0.61 m Fixture

## DETALHES ADICIONAIS DO PRODUTO

---

Tested for compliance to the UBC, NEC®, NBC, and CEC.

## AVISO

---

Os produtos nVent devem ser instalados e utilizados apenas conforme indicado nas fichas de instrução do produto e materiais de treinamento da nVent. As fichas de instrução estão disponíveis em [www.nVent.com](http://www.nVent.com) e com nossos representantes de atendimento ao cliente nVent. A instalação inadequada, uso incorreto, aplicação incorreta ou outra falha qualquer em seguir completamente as instruções e avisos da nVent podem levar ao mau funcionamento do produto, danos à propriedade, lesões corporais graves e morte, e/ou anular sua garantia.

### América do Norte

+1 800 753 9221

Opção 1 – Apoio ao cliente

Opção 2 – Assistência

técnica

### Europa

Países Baixos:

+31 800-0200135

França:

+33 800 901 793

### Europa

Alemanha:

800 1890272

Outros países:

+31 13 5835404

### APAC

Xangai:

+ 86 21 2412 1618/19

Sydney:

+61 2 9751 8500



©2026 nVent. All nVent marks and logos are owned or licensed by nVent Services GmbH or its affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without notice.

This document is system-generated.

[nVent.com/ENDDT](http://nVent.com/ENDDT)

